



Chemical Metering Pumps
www.sidewinderpumps.com

Emergency Shut Down

In the event of an emergency, follow these steps in order:

i) Close air/gas supply isolation ball valve (#5)

ii) Close isolation ball valve (#8) between pump setting gauge (#9) and chemical tank (#7)

iii) Close isolation ball valve (#8) between pump and pump setting gauge (#9)

