RECOMMENDED INSTALLATION OF THE TREATMENT PUMP - FLOW INSTALL NOZZLE WITHIN 45 DEGREES OF VERTICAL FROM BOTTOM OF PIPE INJECTION NOZZLE RETURN LINE -SUPPLY TANK ISOLATION VALVE SAMPLE VALVE PUMP SUPPLY VALVE STRAINER

RECORD PUMP INFORMATION

MODEL NUMBER			
SERIAL NUMBER			
DATE INSTALLED			
NOTES			